

**Niagara Falls Water Board**  
**5815 Buffalo Ave.**  
**Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234  
 Company: Starpoint CSD  
 Address: 4363 Mapleton Rd.  
 Lockport, NY 14094

page 1 of 5

Samples Received: 9/28/2020 @1050

Sample Date & Time: 9/26/2020 @1055		Sampled By: VRCN			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
FRI BLO-OBS	Lead	3.68 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @1105		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
R-4RS	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @1103		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
R-3RS	Lead	0.69 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @1045		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-21RS	Lead	2.05 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @1042		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-22RS	Lead	5.01 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @1040		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-24RS	Lead	2.13 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @0855		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
H-Bycafe-BF	Lead	ND ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @0843		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
Fri Kit Island	Lead	12.90 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

The results relate only to the samples as received from client  
 ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/15/2020  
 Patrick A Fama, Microbiologist



**Niagara Falls Water Board  
5815 Buffalo Ave.  
Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234  
Company: Starpoint CSD  
Address: 4363 Mapleton Rd.  
Lockport, NY 14094

page 2 of 5

Samples Received: 9/28/2020 @1050

Sample Date & Time: 9/26/2020 @1110		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
R-1 RS	Lead	0.91 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @1110		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
R-1BS	Lead	2.84 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @1049		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-23 RS	Lead	3.31 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @1107		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
R-2 BS	Lead	3.27 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @1040		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-20 RS	Lead	2.83 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @1037		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-19 RS	Lead	1.43 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @0909		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
H-19 RS	Lead	5.05 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @0909		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
H-19 BS	Lead	7.80 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

The results relate only to the samples as received from client  
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/15/2020  
Patrick A Fama, Microbiologist

**Niagara Falls Water Board  
5815 Buffalo Ave.  
Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234  
Company: Starpoint CSD  
Address: 4363 Mapleton Rd.  
Lockport, NY 14094

page 3 of 5

Samples Received: 9/28/2020 @1050

Sample Date & Time: 9/26/2020 @1035		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-16 RS	Lead	7.59 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @0850		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
HLFLBSL	Lead	5.45 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sample Date & Time: 9/26/2020 @1026		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-17 RS	Lead	3.41 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sample Date & Time: 9/26/2020 @1036		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-18 RS	Lead	2.32 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sample Date & Time: 9/26/2020 @0851		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
Fri HBL BSL	Lead	11.00 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sample Date & Time: 9/26/2020 @1020		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-10 BS	Lead	3.22 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sample Date & Time: 9/26/2020 @1027		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-14 RS	Lead	6.23 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sample Date & Time: 9/26/2020 @1029		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-MFLBS	Lead	3.30 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

The results relate only to the samples as received from client  
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/15/2020  
Patrick A Fama, Microbiologist

**Niagara Falls Water Board**  
**5815 Buffalo Ave.**  
**Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234  
 Company: Starpoint CSD  
 Address: 4363 Mapleton Rd.  
 Lockport, NY 14094

page 4 of 5

Samples Received: 9/28/2020 @1050

Sample Date & Time: 9/26/2020 @1027 Sampled By: CNVR Sample Type: Grab  

Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-15 RS	Lead	27.15 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sample Date & Time: 9/26/2020 @1028 Sampled By: CNVR Sample Type: Grab  

Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-WFLBS	Lead	0.71 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sample Date & Time: 9/26/2020 @1031 Sampled By: CNVR Sample Type: Grab  

Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-Hall BF	Lead	ND ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sample Date & Time: 9/26/2020 @1020 Sampled By: CNVR Sample Type: Grab  

Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-10 RS	Lead	0.58 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time: 9/26/2020 @1021 Sampled By: CNVR Sample Type: Grab  

Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-12 RS	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	09/30/20	03/30/20	JB

Sample Date & Time: 9/26/2020 @1024 Sampled By: CNVR Sample Type: Grab  

Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-11 RS	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time: 9/26/2020 @1021 Sampled By: CNVR Sample Type: Grab  

Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-12 BS	Lead	6.61 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time: 9/26/2020 @1016 Sampled By: CNVR Sample Type: Grab  

Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-8 BS	Lead	5.52 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

The results relate only to the samples as received from client  
 ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/15/2020  
 Patrick A Fama, Microbiologist

**Niagara Falls Water Board  
5815 Buffalo Ave.  
Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234  
Company: Starpoint CSD  
Address: 4363 Mapleton Rd.  
Lockport, NY 14094

page 5 of 5

Samples Received: 9/28/2020 @1050

Sample Date & Time: 9/26/2020 @1016		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-8 BS	Lead	5.52 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time: 9/26/2020 @0830		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-2 BS	Lead	20.40 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time: 9/26/2020 @0825		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-8 BS	Lead	12.30 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time: 9/26/2020 @1025		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-13 RS	Lead	4.41 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time: 9/26/2020 @1018		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-9 BS	Lead	3.61 ug/L	EPA 200.8	15 ug/L	09/30/20	03/30/20	JB

Sample Date & Time: 9/26/2020 @1018		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-9 RS	Lead	0.56 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time: 9/26/2020 @0827		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-1 BS	Lead	3.97 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time: 9/26/2020 @0840		Sampled By: CNVR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
Fri Kit Hand Sink	Lead	4.25 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

The results relate only to the samples as received from client  
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/15/2020  
Patrick A Fama, Microbiologist