

**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 14094

page 1 of 5

Samples Received: 9/28/2020 @1050

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
9/26/2020 @1016	G-8 RS	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
9/26/2020 @0841	R-4RSFri Kit Window	Lead	7.27 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
9/26/2020 @0839	Fri Boiler BS	Lead	6.43 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
9/26/2020 @0818	J-7 BS	Lead	3.08 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
9/26/2020 @0815	J-9 BS	Lead	20.40 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
9/26/2020 @0815	JR-9 RS	Lead	3.47 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
9/26/2020 @0750	J-20 BS	Lead	1.59 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
9/26/2020 @0745	J-17 RS	Lead	6.37 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/16/2020
Patrick A Fama, Microbiologist



**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 14094

page 2 of 5

Samples Received: 9/28/2020 @1050

Sample Date & Time: 9/26/2020 @0745		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-17 BS	Lead	1.16 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time: 9/26/2020 @0817		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-12 RS	Lead	8.33 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time: 9/26/2020 @0817		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-12 BS	Lead	7.63 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time: 9/26/2020 @0745		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-18 BS	Lead	3.38 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time: 9/26/2020 @0812		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-14 RS	Lead	7.05 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time: 9/26/2020 @0750		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-15 BS	Lead	1.69 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time: 9/26/2020 @0745		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-18 RS	Lead	14.00 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time: 9/26/2020 @0810		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-11 RS	Lead	12.40 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/16/2020
Patrick A Fama, Microbiologist

**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 14094

page 3 of 5

Samples Received: 9/28/2020 @1050

Sample Date & Time: 9/26/2020 @0812		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-14 BS	Lead	2.68 ug/L	EPA 200.8	15 ug/L	09/30/20	09/30/20	JB

Sample Date & Time: 9/26/2020 @0905		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
H Byoffice BF	Lead	ND ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @0844		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
Fri Kit Window 1L	Lead	4.76 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @0903		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
H Office BS	Lead	1.88 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @0903		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
H Office RS	Lead	1.48 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @0851		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
Fri HBL BSR	Lead	7.30 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @0907		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
H-2 BS	Lead	1.43 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @0907		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
H-2 RS	Lead	2.44 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/16/2020
Patrick A Fama, Microbiologist

Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
 Company: Starpoint CSD
 Address: 4363 Mapleton Rd.
 Lockport, NY 14094

page 4 of 5

Samples Received: 9/28/2020 @1050

Sample Date & Time: 9/26/2020 @1005		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-4 RS	Lead	3.75 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @1006		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-3 RS	Lead	28.20 ug/L	EPA 200.8	15 ug/L	10/06/20	10/06/20	JB

Sample Date & Time: 9/26/2020 @1015		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-7 RS	Lead	0.08 ug/L	EPA 200.8	15 ug/L	10/02/20	10/02/20	JB

Sample Date & Time: 9/26/2020 @1000		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-2 RS	Lead	2890.00 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sample Date & Time: 9/26/2020 @0856		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
Fri HGL BSL	Lead	8.57 ug/L	EPA 200.8	15 ug/L	10/02/20	10/02/20	JB

Sample Date & Time: 9/26/2020 @0900		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
HA Office BS	Lead	2.38 ug/L	EPA 200.8	15 ug/L	10/02/20	10/02/20	JB

Sample Date & Time: 9/26/2020 @1001		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-1 RS	Lead	160.00 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sample Date & Time: 9/26/2020 @1015		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-7 BS	Lead	5.75 ug/L	EPA 200.8	15 ug/L	10/02/20	10/02/20	JB

The results relate only to the samples as received from client
 ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/16/2020
 Patrick A Fama, Microbiologist

**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 14094

page 5 of 5

Samples Received: 9/28/2020 @1050

Sample Date & Time: 9/26/2020 @1024		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-11 BS	Lead	5.15 ug/L	EPA 200.8	15 ug/L	10/02/20	10/02/20	JB

Sample Date & Time: 9/26/2020 @0850		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
HLFLBSR	Lead	6.99 ug/L	EPA 200.8	15 ug/L	10/02/20	10/02/20	JB

Sample Date & Time: 9/26/2020 @0852		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
H-3 RS	Lead	1.78 ug/L	EPA 200.8	15 ug/L	10/02/20	10/02/20	JB

Sample Date & Time: 9/26/2020 @0856		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
Fri HGL-BSR	Lead	5.09 ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

Sample Date & Time: 9/26/2020 @0910		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
H-MFL-BSR	Lead	21.70 ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

Sample Date & Time: 9/26/2020 @0850		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
H-1 BS	Lead	5.44 ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

Sample Date & Time: 9/26/2020 @0910		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
HMFLBSR	Lead	8.34 ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

Sample Date & Time: 9/26/2020 @0839		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
Fri-Kit BS	Lead	3.01 ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/16/2020
Patrick A Fama, Microbiologist