

**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 14094

page 1 of 4

Samples Received: 9/28/2020 @1050

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
9/26/2020 @0842	Fri Kit Window 2M	Lead	5.11 ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
9/26/2020 @0827	J-1 BF	Lead	ND ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
9/26/2020 @0830	J-2 RS	Lead	12.90 ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
9/26/2020 @0745	Fri JHall BF	Lead	ND ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
9/26/2020 @0731	J-23 BSR	Lead	7.52 ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
9/26/2020 @0733	J-26 BS	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
9/26/2020 @0820	J-10 RS	Lead	16.80 ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
9/26/2020 @0823	J-3 RS	Lead	4.16 ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/27/2020
Patrick A Fama, Microbiologist



**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 14094

page 2 of 4

Samples Received: 9/28/2020 @1050

Sample Date & Time: 9/26/2020 @0820		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-5 BS	Lead	3.28 ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

Sample Date & Time: 9/26/2020 @0820		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-10 BS	Lead	6.99 ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

Sample Date & Time: 9/26/2020 @0735		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-21 RS	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

Sample Date & Time: 9/26/2020 @0750		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-20 RS	Lead	7.98 ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

Sample Date & Time: 9/26/2020 @0823		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-3 BS	Lead	6.58 ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

Sample Date & Time: 9/26/2020 @0826		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-6 BS	Lead	3.87 ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

Sample Date & Time: 9/26/2020 @0827		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-1 RS	Lead	2.12 ug/L	EPA 200.8	15 ug/L	09/29/20	09/29/20	JB

Sample Date & Time: 9/26/2020 @0730		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-28 BSL	Lead	4.83 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/27/2020
Patrick A Fama, Microbiologist

**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 14094

page 3 of 4

Samples Received: 9/28/2020 @1050

Sample Date & Time: 9/26/2020 @0733		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-26 RS	Lead	0.59 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

Sample Date & Time: 9/26/2020 @0735		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-21-BS	Lead	7.21 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

Sample Date & Time: 9/26/2020 @0731		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-23 BSL	Lead	8.38 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

Sample Date & Time: 9/26/2020 @0730		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-28 BSR	Lead	0.68 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

Sample Date & Time: 9/26/2020 @0810		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-11 BS	Lead	164.00 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

Sample Date & Time: 9/26/2020 @0807		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-16 RS	Lead	8.36 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

Sample Date & Time: 9/26/2020 @0750		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-15 RS	Lead	11.40 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

Sample Date & Time: 9/26/2020 @0805		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-13 BS	Lead	4.85 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/27/2020
Patrick A Fama, Microbiologist

Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 14094

page 4 of 4

Samples Received: 9/28/2020 @1050

Sample Date & Time: 9/26/2020 @0805		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-13 RS	Lead	326.00 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB
Sample Date & Time: 9/26/2020 @0807		Sampled By: CN/VR			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
J-16 BS	Lead	9.81 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

The results relate only to the samples as received from client
ND = not detected in sample

Manager : Patrick Fama (LBS) Date: 10/27/2020
Patrick A Fama, Microbiologist