

**Niagara Falls Water Board  
5815 Buffalo Ave.  
Niagara Falls, NY 14304**

Phone: (716)283-10770 x 2050 Fax: (716)283-10748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234  
Company: Starpoint CSD  
Address: 4363 Mapleton Rd.  
Lockport, NY 140104

page 1 of 5

Samples Received: 10/05/2020 @1015

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0710	F-LMC BS	Lead	4.47 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0722	BLRO-BS	Lead	0.85 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0725	BLR-BS	Lead	6.09 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0731	AAhall-BF	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0733	AA-20-RSL	Lead	4.29 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0734	AA-20-RSR	Lead	4.26 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0738	AA-19-RS	Lead	4.97 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0741	AA-18-RS	Lead	2.51 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

The results relate only to the samples as received from client  
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/30/2020  
Patrick A Fama, Microbiologist



**Niagara Falls Water Board  
5815 Buffalo Ave.  
Niagara Falls, NY 14304**

Phone: (716)283-10770 x 2050 Fax: (716)283-10748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234  
Company: Starpoint CSD  
Address: 4363 Mapleton Rd.  
Lockport, NY 140104

page 2 of 5

Samples Received: 10/05/2020 @1015

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0744	AA-17-RS	Lead	3.12 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0746	AA-16-RS	Lead	2.49 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0751	AA-15-RS	Lead	2.76 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0755	A-MO-BS	Lead	3.41 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0758	A-1RS-1L	Lead	2.35 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0800	A-1RS-2L	Lead	4.76 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0802	A-1RS-M	Lead	2.09 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0804	A-1RS-1R	Lead	3.53 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

The results relate only to the samples as received from client  
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/30/2020  
Patrick A Fama, Microbiologist



**Niagara Falls Water Board  
5815 Buffalo Ave.  
Niagara Falls, NY 14304**

Phone: (716)283-10770 x 2050 Fax: (716)283-10748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234  
Company: Starpoint CSD  
Address: 4363 Mapleton Rd.  
Lockport, NY 140104

page 3 of 5

Samples Received: 10/05/2020 @1015

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0806	A-1RS-R2	Lead	2.48 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0809	A-3-RS	Lead	2.71 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0812	A-5-RS	Lead	1.70 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0816	A-6-RS	Lead	1.65 ug/L	EPA 200.8	15 ug/L	10/13/20	10/13/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0819	A-7-RS	Lead	2.03 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0822	A-6-RS	Lead	2.88 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0823	A-8-RS	Lead	1.74 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @08250	A-8-BS	Lead	3.99 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

The results relate only to the samples as received from client  
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/30/2020  
Patrick A Fama, Microbiologist



**Niagara Falls Water Board  
5815 Buffalo Ave.  
Niagara Falls, NY 14304**

Phone: (716)283-10770 x 2050 Fax: (716)283-10748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234  
Company: Starpoint CSD  
Address: 4363 Mapleton Rd.  
Lockport, NY 140104

page 4 of 5

Samples Received: 10/05/2020 @1015

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0829	A-9-RS	Lead	1.58 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0830	A-11-RS	Lead	1.35 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0831	A-13-RS	Lead	1.26 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0833	A-14-RS	Lead	0.93 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0836	A-12-RS	Lead	1.43 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0838	A-12-BS	Lead	2.38 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0840	A-10-RS	Lead	1.57 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0842	A-10-BS	Lead	3.41 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

The results relate only to the samples as received from client  
ND = not detected in sample

Manager: Patrick Fama (LBS)  
Patrick A Fama, Microbiologist

Date: 10/30/2020



**Niagara Falls Water Board  
5815 Buffalo Ave.  
Niagara Falls, NY 14304**

Phone: (716)283-10770 x 2050 Fax: (716)283-10748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234  
Company: Starpoint CSD  
Address: 4363 Mapleton Rd.  
Lockport, NY 140104

page 5 of 5

Samples Received: 10/05/2020 @1015

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0842	A-10-BS	Lead	3.41 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0847	INT-GLR-BS	Lead	0.94 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0849	INT-BGYM-DF	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0854	AA-HALL-DF	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0928	INT-KIT-WIN I	Lead	0.80 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0925	INT-KIT-WIN-R	Lead	2.03 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0933	INT-KIT-DEEP BAY DF	Lead	1.96 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0935	INT-KIT-(ISLAND-PRE	Lead	3.25 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

The results relate only to the samples as received from client  
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/30/2020  
Patrick A Fama, Microbiologist

