

**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-10770 x 2050 Fax: (716)283-10748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 140104

page 1 of 6

Samples Received: 10/05/2020 @1015

Sample Date & Time: 10/03/2020 @0937 Sampled By: DE SM Sample Type: Grab

Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
INT-KIT-HAND	Lead	0.74 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sample Date & Time: 10/03/2020 @0941 Sampled By: DE SM Sample Type: Grab

Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
INT-KIT-DISH	Lead	0.90 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sample Date & Time: 10/03/2020 @0943 Sampled By: DE SM Sample Type: Grab

Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
B-B-LAV-BS	Lead	2.00 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sample Date & Time: 10/03/2020 @0945 Sampled By: DE SM Sample Type: Grab

Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
G-B-LAV-BS	Lead	2.99 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sample Date & Time: 10/03/2020 @0947 Sampled By: DE SM Sample Type: Grab

Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
INT-NO-RS	Lead	2.88 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sample Date & Time: 10/03/2020 @0949 Sampled By: DE SM Sample Type: Grab

Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
INT-NO-BS	Lead	4.07 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sample Date & Time: 10/03/2020 @0951 Sampled By: DE SM Sample Type: Grab

Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
B-13-a-BS	Lead	15.30 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sample Date & Time: 10/03/2020 @0956 Sampled By: DE SM Sample Type: Grab

Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
B-14-RS	Lead	1.57 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

The results relate only to the samples as received from client
 ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 11/03/2020
 Patrick A Fama, Microbiologist



**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-10770 x 2050 Fax: (716)283-10748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 140104

page 2 of 6

Samples Received: 10/05/2020 @1015

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @0958	B-R-R-RS	Lead	1.28 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1001	B-9-RS	Lead	6.38 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1003	B-11-RS	Lead	1.10 ug/L	EPA 200.8	15 ug/L	10/27/20	10/27/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1008	C-1-RS	Lead	2.49 ug/L	EPA 200.8	15 ug/L	10/14/20	10/14/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1009	C-1-BS	Lead	3.34 ug/L	EPA 200.8	15 ug/L	10/14/20	10/14/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1012	C-2-RS	Lead	3.26 ug/L	EPA 200.8	15 ug/L	10/14/20	10/14/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1012	C-2-BS	Lead	1.89 ug/L	EPA 200.8	15 ug/L	10/14/20	10/14/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1015	C-3-RS	Lead	1.80 ug/L	EPA 200.8	15 ug/L	10/14/20	10/14/20	JB

Sampled By: DE SM

Sample Type: Grab

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS)
Patrick A Fama, Microbiologist

Date: 11/03/2020



**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-10770 x 2050 Fax: (716)283-10748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 140104

page 3 of 6

Samples Received: 10/05/2020 @1015

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1016	C-3-BS	Lead	3.00 ug/L	EPA 200.8	15 ug/L	10/14/20	10/14/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1018	C-4-RS	Lead	2.50 ug/L	EPA 200.8	15 ug/L	10/14/20	10/14/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1019	C-4-BS	Lead	2.50 ug/L	EPA 200.8	15 ug/L	10/14/20	10/14/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1024	C-6-RS	Lead	2.02 ug/L	EPA 200.8	15 ug/L	10/14/20	10/14/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1026	C-6-BS	Lead	1.82 ug/L	EPA 200.8	15 ug/L	10/14/20	10/14/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1028	C-5-RS	Lead	3.56 ug/L	EPA 200.8	15 ug/L	10/14/20	10/14/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1029	C-5-BS	Lead	2.66 ug/L	EPA 200.8	15 ug/L	10/14/20	10/14/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1032	C-7-RS	Lead	1.79 ug/L	EPA 200.8	15 ug/L	10/14/20	10/14/20	JB

Sampled By: DE SM

Sample Type: Grab

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 11/03/2020
Patrick A Fama, Microbiologist



**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-10770 x 2050 Fax: (716)283-10748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 140104

page 4 of 6

Samples Received: 10/05/2020 @1015

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1033	C-7-BS	Lead	1.50 ug/L	EPA 200.8	15 ug/L	10/14/20	10/14/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1035	C-8-RS	Lead	6.35 ug/L	EPA 200.8	15 ug/L	10/14/20	10/14/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1036	C-8-BS	Lead	1.72 ug/L	EPA 200.8	15 ug/L	10/14/20	10/14/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1039	C-9-RS	Lead	3.35 ug/L	EPA 200.8	15 ug/L	10/14/20	10/14/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1040	C-9-BS	Lead	2.00 ug/L	EPA 200.8	15 ug/L	10/14/20	10/14/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1046	C-10-RS	Lead	1.23 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1047	C-10-BS	Lead	3.35 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1049	C-11-RS	Lead	2.02 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

Sampled By: DE SM

Sample Type: Grab

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 11/03/2020
Patrick A Fama, Microbiologist



**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-10770 x 2050 Fax: (716)283-10748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 140104

page 5 of 6

Samples Received: 10/05/2020 @1015

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1050	C-11-BS	Lead	2.03 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1054	C-12-RS	Lead	1.28 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1055	C-12-BS	Lead	4.00 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1058	C-13-RS	Lead	1.50 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1059	C-13-BS	Lead	2.36 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1101	C-14-RS	Lead	2.42 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1103	C-14-BS	Lead	2.09 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

Sampled By: DE SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/03/2020 @1107	C-15-BS	Lead	2.40 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

Sampled By: DE SM

Sample Type: Grab

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS)
Patrick A Fama, Microbiologist

Date: 11/03/2020



**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-10770 x 2050 Fax: (716)283-10748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 140104

page 6 of 6

Samples Received: 10/05/2020 @1015

Sample Date & Time: 10/03/2020 @1110		Sampled By: DE SM			Sample Type: Grab		
Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
C-16-BS	Lead	2.93 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB
Sample Date & Time: 10/03/2020 @1114		Sampled By: DE SM			Sample Type: Grab		
C-17-BS	Lead	2.49 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB
Sample Date & Time: 10/03/2020 @1116		Sampled By: DE SM			Sample Type: Grab		
C-18-BS	Lead	2.26 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB
Sample Date & Time: 10/03/2020 @1120		Sampled By: DE SM			Sample Type: Grab		
C-7-HALL BF	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	10/23/20	10/23/20	JB

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 11/03/2020
Patrick A Fama, Microbiologist

