

**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 14094

page 1 of 5

Samples Received: 10/13/2020 @1115

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0630								
	MSKE3RS	Lead	3.94 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0632								
	MSKRS1	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0633								
	MSKRS2	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0634								
	MSKRFS	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0635								
	MSKSP	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0637								
	MSKRS3	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0639								
	MSKHS3	Lead	0.62 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0640								
	MSKDR51	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS)
Patrick A Fama, Microbiologist

Date: 10/06/2020



**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 14094

page 2 of 5

Samples Received: 10/13/2020 @1115

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0643	MSKDR52	Lead	0.59 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sampled By: SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0644	MSKDW	Lead	0.57 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sampled By: SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0649	MSCBBL	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sampled By: SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0650	MSCBBSR	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sampled By: SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0652	MSCGBSL	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sampled By: SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0654	MSCBGSR	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sampled By: SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0655	MSCBF	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sampled By: SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0658	MSLBF	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sampled By: SM

Sample Type: Grab

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS)
Patrick A Fama, Microbiologist

Date: 10/06/2020



**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 14094

page 3 of 5

Samples Received: 10/13/2020 @1115

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0707	MSG7BS	Lead	8.09 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sampled By: SM/DE

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0710	MSGLO16BS	Lead	15.60 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sampled By: SM/DE

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0713	MSGLBSN	Lead	6.75 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sampled By: SM/DE

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0714	MSGLBSS	Lead	5.62 ug/L	EPA 200.8	15 ug/L	10/29/20	10/29/20	JB

Sampled By: SM/DE

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0718	MSGLBSS	Lead	9.36 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0722	MSGLO27RS	Lead	12.00 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0723	MSBLO25RS	Lead	23.20 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0725	MSBLRBSL	Lead	5.05 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/06/2020
Patrick A Fama, Microbiologist



**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 14094

page 4 of 5

Samples Received: 10/13/2020 @1115

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0726	MSBLRBSR	Lead	10.10 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0728	MSBLRCBS	Lead	3.38 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0732	MSFRBF	Lead	ND ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0734	MSFRGSL	Lead	1.05 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0735	MSFRGSR	Lead	3.71 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0738	MSFRBSL	Lead	1.96 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0740	MSFRBRSR	Lead	0.54 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0744	MSFGRS	Lead	11.20 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/06/2020
Patrick A Fama, Microbiologist



**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 14094

page 5 of 5

Samples Received: 10/13/2020 @1115

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0748	F7RSW	Lead	6.08 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0750	F7RSE	Lead	8.32 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0751	F7RSN	Lead	0.87 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0753	F7RSI	Lead	0.55 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0753	F7RSM	Lead	0.75 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0754	F7RSS	Lead	8.06 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0755	F7RSH	Lead	1.91 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/10/2020 @0758	MSFLGIL	Lead	17.40 ug/L	EPA 200.8	15 ug/L	10/30/20	10/30/20	JB

Sampled By: DE/SM

Sample Type: Grab

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 10/06/2020
Patrick A Fama, Microbiologist

