

**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 14094

page 1 of 4

Samples Received: 10/19/2020 @1110

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1015	L17-RSL	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1015	L17-RSR	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1020	L18-RSL	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1020	L18-RSR	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1030	M10-RS	Lead	0.66 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1035	WRO-RS	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1035	WRO-BS	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1100	L6-RS	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS) Date: 11/24/2020
Patrick A Fama, Microbiologist



**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 14094

page 2 of 4

Samples Received: 10/19/2020 @1110

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1105	L5-RS	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1110	L4-RS	Lead	0.78 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1113	L2-RS	Lead	0.57 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1113	L2-BS	Lead	1.75 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1115	M1-RS	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1120	M4a-RSL	Lead	2.66 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1120	M4a-RSR	Lead	1.40 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1125	M4-RS	Lead	0.97 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

The results relate only to the samples as received from client
ND = not detected in sample

Manager Patrick Fama (LBS)
Patrick A Fama, Microbiologist

Date: 11/24/2020



**Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304**

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 14094

page 3 of 4

Samples Received: 10/19/2020 @1110

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1125	M4-Wall	Lead	0.99 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1130	M4-Spray	Lead	1.17 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1130	M4-Dspray	Lead	0.62 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1133	M4-DSL	Lead	0.70 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1133	M4-DSM	Lead	0.77 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1133	M4-DSR	Lead	0.73 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1137	M4-ROUND K	Lead	2.55 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

Sample Date & Time	Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
10/17/2020 @1137	M4-SQUARE	Lead	1.14 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sampled By: VR/SH

Sample Type: Grab

The results relate only to the samples as received from client
ND = not detected in sample

Manager: Patrick Fama (LBS)
Patrick A Fama, Microbiologist

Date: 11/24/2020



Niagara Falls Water Board
5815 Buffalo Ave.
Niagara Falls, NY 14304

Phone: (716)283-9770 x 2050 Fax: (716)283-9748 pfama@nfwb.org

Lab ID #10411

FINAL LABORATORY REPORT - 2020 Lead Analysis

Name: Sean Healy Phone: (716) 735-7234
Company: Starpoint CSD
Address: 4363 Mapleton Rd.
Lockport, NY 14094

page 4 of 4

Samples Received: 10/19/2020 @1110

Sample Date & Time: 10/17/2020 @1140 Sampled By: VR/SH Sample Type: Grab

Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
MM-BF	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

Sample Date & Time: 10/17/2020 @1145 Sampled By: VR/SH Sample Type: Grab

Sample Location	Test	Result	Method	MCL	Analysis Start	Analysis End	Analyst
WR-BF	Lead	<0.50 ug/L	EPA 200.8	15 ug/L	11/20/20	11/20/20	JB

The results relate only to the samples as received from client
ND = not detected in sample

Manager : Patrick Fama (LBS) Date: 11/24/2020
Patrick A Fama, Microbiologist

