

A MEMBER OF THE STOHL GROUP OF COMPANIES

## 1.2 Executive Summary of Sampling and Analysis:

### Total Number of Samples Collected by Building Classified by First Draw & Confirmatory Samples:

Building Name	Date of Sample Event	Total Number Samples Collected	First Draw Samples		Confirmatory Samples **	
			Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb	Number of Samples Below Action level of 15 ppb	Number of Samples Above Action Level of 15 ppb
Starpoint High School	10/29/2016, 3/9/2017, 4/19/2017	267***	229	38	0	0

\*\* Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

\*\*\* Samples 116.4-155, 116.4-157, 116.4-168, 116.4-174, 116.4-183, and 116.4-193 were either damaged or lost in transit to the lab during the sampling events on 10/29/2016 and 3/9/2017; they were not analyzed by the lab. At the direction of the District, follow-up sampling on 4/19/2017 did not include these 6 outlets because they were either designated "not for potable use" or permanently removed from service

### Listing of Outlets Requiring Remediation:

Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples and Confirmatory Samples				
Sample #	Sample Type	Classroom or other Location	Fixture / Outlet type	Laboratory Analysis in ppb
116.4-2	First Draw	MS Boy's Bathroom D Wing, Center	Sink	18.4
116.4-3	First Draw	MS Boy's Bathroom D Wing, Right	Sink	16.4
116.4-4	First Draw	MS Boy's Bathroom D Wing	Hose Bib	195
116.4-15	First Draw	Under Pool	Hose Bib	175
116.4-32	First Draw	Boy's Bathroom, Near K-22	Hose Bib	15.2
116.4-40	First Draw	Girl's Bathroom, Near K-17	Hose Bib	52.7
116.4-53	First Draw	Room K-6, K-8 Wall, Right	Sink	17.8
116.4-56	First Draw	Room K-6, Right Island (Facing Windows), Windows	Sink	32.5
116.4-58	First Draw	Room K-6, Left Island (Facing Windows), Center	Sink	30.2
116.4-66	First Draw	Room K-4, HS Office Wall, Right	Sink	55.0
116.4-67	First Draw	Room K-4, HS Office Wall, Left	Sink	92.2
116.4-68	First Draw	Room K-4, Left Island (Facing Windows), Hall	Sink	30.2
116.4-69	First Draw	Room K-4, Left Island (Facing Windows), Center	Sink	37.0



ENVIRONMENTAL CONSULTANTS

4169 Allendale Parkway  
 Buffalo, New York 14219  
 (P) 716-312-0070 (F) 716-312-8092  
 www.stohlenvironmental.com

A MEMBER OF THE STOHL GROUP OF COMPANIES

**Locations of Outlets Analyzed above the NYS Action Level of 15 parts per billion based upon Analysis of First Draw Samples and Confirmatory Samples Continued**

Sample #	Sample Type	Classroom or other Location	Fixture / Outlet type	Laboratory Analysis in ppb
116.4-70	First Draw	Room K-4, Left Island (Facing Windows), Windows	Sink	43.9
116.4-71	First Draw	Room K-4, Right Island (Facing Windows), Hall	Sink	56.2
116.4-72	First Draw	Room K-4, Right Island (Facing Windows), Center	Sink	37.5
116.4-73	First Draw	Room K-4, Right Island (Facing Windows), Windows	Sink	57.9
116.4-81	First Draw	Women's Bathroom, Adjacent to Library	Sink	18.5
116.4-82	First Draw	Women's Bathroom, Adjacent to Library	Hose Bib	147
116.4-83	First Draw	Men's Bathroom, Adjacent to Library	Sink	16.2
116.4-84	First Draw	Men's Bathroom, Adjacent to Library	Hose Bib	549
116.4-88	First Draw	Men's Bathroom, HS Office	Hose Bib	23.3
116.4-133	First Draw	Boy's Locker-room, Staff Bathroom	Hose Bib	16.6
116.4-137	First Draw	Boy's Locker-room, Bathroom, Left	Sink	16.7
116.4-141	First Draw	Locker -Room, Men's Official	Hose Bib	516
116.4-148	First Draw	Girl's Locker, Bathroom Left	Sink	77.5
116.4-149	First Draw	Girl's Locker, Bathroom Center	Sink	18.0
116.4-150	First Draw	Girl's Locker, Bathroom Right	Sink	45.2
116.4-154	First Draw	Girls Locker, Team	Sink	26.6
116.4-156	First Draw	Girl's Locker, Team Coach's	Sink	17.7
116.4-164	First Draw	Men's Bathroom, Near L17, Left Center	Sink	22.0
116.4-167	First Draw	Men's Bathroom, Near L17, Right	Sink	15.2
116.4-198	First Draw	Boy's Bathroom, Near N23	Hose Bib	29.4
116.4-212	First Draw	Room N7, Bathroom	Hose Bib	16.5
116.4-231	First Draw	Room N3, Left	Sink	29.8
116.4-233	First Draw	Room N3, Right	Sink	31.3
116.4-234	First Draw	Room N5, Hood	Sink	24.0
116.4-237	First Draw	Room N4, Hood	Sink	31.2